

6/27/201

<u>AREA</u>	<u>FAILURE</u>	<u>PROBLEM</u>	<u>PROBLEM DESCRIPTION</u>	<u>FINISH DATE</u>	<u>wonum</u>
WSHYDRAN WSHYDRAN	WHYDRANT	LEAKING	leaking at bonnet; pg&t 11B	June 21, 2012	529411
WSHYDRAN	WHYDRANT	NONOP	2 1/2" nuts are loose 11C	June 25, 2012	532391
WSHYDRAN	WHYDRANT	LEAKING	leaking 25B CCSD Nicholson Elem	June 20, 2012	531728
WSSTANDB WSSTANDB	WSVCLINE	LEAK	Water Leak @ 4906 Hawk Trl	June 24, 2012	534632
WSSTANDB	WSVCLINE	NOWATER	NO WATER @ 431 MARK AVENUE	June 25, 2012	535055
WSSTANDB	WSVCLINE	LEAK	Water Leak @ 4351 Collins Cir	June 20, 2012	531203
WSSWING WSSWING	WSVCLINE	LEAK	WATER LEAK @ 11 FLINT RIDGE DR	June 20, 2012	531984
WSSWING	WSVCLINE	LEAK	water leak @ 6118 Brookmere Place	June 21, 2012	532689
WSSWING	WSVCLINE	LEAK	WATER LEAK @ 4552 Coopers Creek PI	June 26, 2012	535292
WSSWING	WSVCLINE	LEAK	water leak @ 5887 Buckner Creek Drive	June 22, 2012	532788
WSSWING	WHYDRANT	LEAKING	water fire hydrant leak @ 4297 FoxWood Ct	June 20, 2012	531982
WSSWING	SSGRAVMAIN	BLOCKAGE	Sewer Backup @ 2002 Dobbins Dr	June 21, 2012	532693
WSSWING	SSMANHOLE	BROKECONCRETE	BROKEN CONCRETE @ 2730 Country Ln	June 23, 2012	534187
WSSWING	SSMANHOLE	BROKECONCRETE	Sewer manhole @ 1372 Siesta lane	June 22, 2012	534183
WSSWING	WMAIN	BROKEN	Water leak @ Willow Ridge Drive and Willow Ridge	June 20, 2012	531712
WSSWING	WSVCLINE	NOWATER	No Water @ 3578 Turtle Cove Court	June 20, 2012	532352
WSSWING	WSVCLINE	NOWATER	NO WATER @ 4105 Ewing Rd	June 23, 2012	534188
WSSWING	WSVCLINE	NOWATER	NO WATER @ 5044 Laurel Springs Way	June 21, 2012	532695
WSSWING	WMETER	NOWATER	NO WATER @ 3288 Timberloch Dr	June 23, 2012	534186
WSSWING	WSVCLINE	LEAK	water leak @ 1626 Sams Street	June 22, 2012	532773
WSSWING	WMAIN	LEAK	Water leak @ 2103 South Cobb Parkway	June 23, 2012	532697
WSZONE1 WSZONE1	WSVCLINE	LEAK	Repair Longside Service Leak @ 2690 LAUREL LN	June 22, 2012	530793

6/27/201

<u>AREA</u>	<u>FAILURE</u>	<u>PROBLEM</u>	<u>PROBLEM DESCRIPTION</u>	<u>FINISH DATE</u>	<u>wonum</u>
WSZONE1	SSGRAVMAIN	BLOCKAGE	1410 PINE SPRINGS DRIVE	June 22, 2012	532756
WSZONE1	WSVCLINE	LEAK	Water damage @ 5245 Lower Roswell Road	June 20, 2012	531537
WSZONE1	SSMANHOLE	ADJUSTMENT	Sewer odor @ 563 Owl Creek Drive	June 25, 2012	535089
WSZONE1	SSMANHOLE	BLOCKAGE	INVESTIGATE SEWER ODOR @ 1665 NORTH HC	June 25, 2012	535108
WSZONE1	SSTAP	BLOCKAGE	Replace Tap @ 4456 LAKESHORE DRIVE	June 20, 2012	506795
WSZONE1	SSTAP	BLOCKAGE	Repair Tap @ 2879 RHONDA DALE DR	June 21, 2012	528262
WSZONE1	SSTAP	BLOCKAGE	Replace Tap @ 3004 TWELVE OAKS CIR	June 25, 2012	505302
WSZONE1	WSVCLINE	LEAK	Repair Short Side Service Leak @ 3294 SPRINGW.	June 22, 2012	532763
WSZONE1	WSVCLINE	LEAK	Replace Longside Cir 1 1/2 Water Service @ 4351 (June 21, 2012	531748
WSZONE1	WSVCLINE	LEAK	INVESTIGATE WATER LEAK @ 2086 MORGAN R	June 22, 2012	530819
WSZONE1	WSVCLINE	WTRQUALITY	DISCOLORED WATER @ 4591 SPRING STREET	June 20, 2012	531764
WSZONE1	SSTAP	SINKHOLE	Sinkhole @ 1350 Benbrooke Ln.	June 20, 2012	531756
WSZONE2					
WSZONE2	SSGRAVMAIN	CCTV	CCTV Camera Truck - Locate Tap /Z4/ @ 2674 IRE	June 25, 2012	531772
WSZONE2	SSGRAVMAIN	CCTV	CCTV Camera Truck - Lateral /Z1/ @ 1350 BENBR	June 20, 2012	531455
WSZONE2	SSTAP	BLOCKAGE	SEWER BACKUP @ 1809 AUSTELL ROAD	June 20, 2012	531444
WSZONE2	SSTAP	BLOCKAGE	Dig-up @ 4604 Shamrock Place	June 25, 2012	529519
WSZONE2	SSTAP	SMOKEDYETEST DYE/SMOKE TEST @ 6270 BENNETT LN		June 21, 2012	531535
WSZONE2	WSVCLINE	LEAK	Water leak @ 5770 Hill Road	June 21, 2012	531418
WSZONE2	WSVCLINE	LEAK	Water or Sewer Leak @ Cheatham Woods Dr	June 20, 2012	531545
WSZONE2	SSGRAVMAIN	CCTV	CCTV Camera Truck - Tap /Z2/ @ 1484 MILFORD	June 21, 2012	531421
WSZONE2	SSGRAVMAIN	CCTV	Camera Truck Z3 - CCTV Mains and Taps @ Cabre	June 26, 2012	530823
WSZONE3					
WSZONE3	WMAIN	LEAK	Water Leak @ 1101 Eastside Drive	June 26, 2012	535250
WSZONE3	WMAIN	BROKEN	WATER LEAK @ 511 PINE VALLEY ROAD	June 20, 2012	531761

6/27/201

<u>AREA</u>	<u>FAILURE</u>	<u>PROBLEM</u>	<u>PROBLEM DESCRIPTION</u>	<u>FINISH DATE</u>	<u>wonum</u>
WSZONE3	SSMANHOLE	BROKECONCRETE	Inspect Manhole @ 1836 MALLARD LAKE DR	June 20, 2012	531424
WSZONE3	SSMANHOLE	BLOCKAGE	Manhole Overflow @ 521 Village Trace	June 22, 2012	532767
WSZONE3	WSVCLINE	LEAK	WATER LEAK @ 79 GATESIDE PL	June 26, 2012	535188
WSZONE3	WSVCLINE	LEAK	WATER LEAK @ 1493 Little Willeo Rd	June 25, 2012	530994
WSZONE3	WSVCLINE	LEAK	Water Leak @ 3621 Ridge Rd	June 20, 2012	531437
WSZONE4					
WSZONE4	WSVCLINE	LEAK	WATER LEAK @ 2270 TURTLE CLUB DRIVE	June 22, 2012	531559
WSZONE4	WSVCLINE	LEAK	REPLACE SERVICE LINE @ 4752 NORTH SPRING	June 20, 2012	530987
WSZONE4	WSVCLINE	LEAK	Replace Leak @ 4657 JEFFERSON TOWNSHIP LI	June 20, 2012	529231
WSZONE4	WMAIN	LEAK	Water Leak @ 2022 North Cove Ct	June 20, 2012	529630
WSZONE4	WMAIN	BROKEN	Water Leak @ 2111 NORTH LANDING CT	June 21, 2012	531770
WSZONE4	WMAIN	BROKEN	Water Leak @ 4049 Leicester Dr	June 25, 2012	535065
WSZONE4	WVALVE	ADJUSTMENT	INSPECT WATER VALVE @ 2097 STANRICH CT	June 22, 2012	532394
WSZONE4	SSSTRMCROSS	WASHEDOUT	8" PVC pipe Exposed @ 3428 Weymouth Ct	June 25, 2012	531456
WSZONE4	WSVCLINE	LEAK	Water Leak @ 2369 CAJUN DR	June 22, 2012	529631
WSZONE4	WSVCLINE	LEAK	Replace Service Line @ 431 MARK AVENUE	June 25, 2012	535085

6/27/201

AREA

FAILURE

PROBLEM

PROBLEM DESCRIPTION

FINISH DATE

Total Number of work orders

wonum
60

6/27/201

<u>AREA</u>	<u>FAILURE</u>	<u>PROBLEM</u>	<u>PROBLEM DESCRIPTION</u>	<u>FINISH DATE</u>	<u>wonum</u>
-------------	----------------	----------------	----------------------------	--------------------	--------------